



CHART "A"

FIRESTICK PROFILE	NOMINAL GAP	+/- VERT. MOVEMENT	TOTAL DEFLECTION
FS1	1/2"	1/2"	1"
FS2	1"	1"	2"

- NOTES:**
1. Cyclical Design - UL 2079 Test Standard.
  2. Do not screw drywall or stud to track.
  3. Track Leg min. 1/2" longer than total deflection.
  4. Consult manufacturer on track movement capabilities.
  5. Reference ITS / Warnock Hersey directory for specific information.
  6. Reference UL Fire Resistance Directory for specific information.

HEAD OF WALL SYSTEM 2, AT CONCRETE DECK.  
1 AND 2 HOUR FIRE RESISTANT ASSEMBLY  
(SEE UL LISTING FOR WALL FIRE RATING).

S2G C  
FS 1/2

UL-2079 TEST STD.